



Commonwealth of Massachusetts  
Executive Office of Energy & Environmental Affairs

# Department of Environmental Protection

Western Regional Office • 436 Dwight Street, Springfield MA 01103 • 413-784-1100

Maura T. Healey  
Governor

Kimberley Driscoll  
Lieutenant Governor

Rebecca L. Tepper  
Secretary

Bonnie Heiple  
Commissioner

July 7, 2023

Sent Via First Class and Electronic Mail

Re: New Salem/Wendell

[sullivan@swiftriverschool.org](mailto:sullivan@swiftriverschool.org)

Ms. Kelley Sullivan  
Swift River School  
201 Wendell Rd.  
New Salem, MA 01103

Swift River School  
PWS ID # 1204001  
ENF # 00015906  
Issuing Bureau: BWR  
Issuing Region/Office: Western  
Issuing Program: DWP

## Termination of Boil Order

Dear Ms. Sullivan:

On July 7, 2023, The Massachusetts Department of Environmental Protection (“MassDEP”) issued in writing Unilateral Administrative Order UAO-00015906, the Boil Order (the “Order”) to Swift River School Water system (the “PWS”). Based upon MassDEP’s review of the actions taken by the PWS, MassDEP hereby terminates paragraph 6. A. which requires the PWS to provide notification to consumers of Swift River School to boil their tap water before using for purposes of consumption. This termination covers paragraph 6.A. of the Order only. All other provisions of the Order shall remain in full force and effect.

MassDEP has reviewed the following actions:

- Repeat sampling of 5 Raw Source Water samples showed the presence of Total Coliform in 2 samples but no *E. coli* was detected in any of the 5 samples.
- All distribution samples were absent of Total Coliform.

Swift River School is now required to provide the enclosed public notice to its customers in its Well 01G service area. Posting and distribution of the public notice must be completed in the same manner as the Boil Water Public Notice, in accordance with the provisions of 310 CMR 22.16. If

Y:\DWPArchive\WERO\NewSalem-1204001-Enforcement-2023-07-10  
This information is available in alternate format. Please contact Melixza Esenyie at 617-626-1282.  
TTY# MassRelay Service 1-800-439-2370  
MassDEP Website: [www.mass.gov/dep](http://www.mass.gov/dep)

Printed on Recycled Paper

you have any questions about the contents of this termination letter, please contact Linda Tims, at 413-348-7159.

Respectfully,

Douglas Paine  
Acting Section Chief  
Drinking Water Program

cc: Board of Health  
Certified Operator  
MassDEP/DWP Boston

Ecc: Kelley Sullivan-Swift River School- [sullivan@swiftriverschool.org](mailto:sullivan@swiftriverschool.org)  
Eric Shufelt – Swift River School – [shefelt@swiftriverschool.org](mailto:shefelt@swiftriverschool.org)  
Jared Whitney-WhiteWater, Inc.- [JWhitney@RHWhite.com](mailto:JWhitney@RHWhite.com)  
MassDPH, Community Health, 250 Washington Street, Boston, MA 02108  
Attn: Stephen Hughes  
MassDPH, Bureau of Environmental Health Assessment, 250 Washington Street, Boston, MA  
02108 Attn: Jan Sullivan  
DPH, Division of Epidemiology, Immunization and Communicable Diseases, 305 South Street,  
Jamaica Plain, MA 02130, Attn: Patricia Kludt

W:\BWR\WS\Enforcement\Boil Orders\12040012023-07-10 BoilOrd Term SwiftRiver